

Accuracy Assessment  
of  
DMG DMC50V  
for  
Thomas Keating Ltd  
March 2009

**C. D. Measurements Ltd**

**SPECIALISTS IN ENGINEERING METROLOGY**

Chomlea House, Hadfield Road, Hadfield, Glossop,  
Derbyshire, SK13 2ER.

Tel: 01457 852929. Fax: 01457 860619.

## Site Report

Customer : Thomas Keating Ltd  
Station Mills  
Billingshurst  
West Sussex  
RH14 9SH

Machine : DMG DMC50V

Serial number : 2880-0338

Calibration type : Positional

Calibrated by : A J Gregory

Date : 20 Mar 2009

Equipment : Agilent 5529 laser interferometer

Calibration ref : C71/09-DMG

Certificate no : 02667

## Linear Axis Positional sign convention.

The convention for determining the value and direction of error is found by the following subtraction:-

$$\text{Error} = \text{Laser Reading (Reference)} - \text{Machine Reading (Command)}$$

This convention holds true to the machine tools own sign convention with respect to the resultant direction in which the axis error lies.

For example in a positive moving axis:-

$$\text{Error} = (2000.147\text{mm}) - (2000.000\text{mm}) = +0.147\text{mm Overtravel.}$$

$$\text{Error} = (1999.983\text{mm}) - (2000.000\text{mm}) = -0.017\text{mm Undertravel.}$$

And in a negative moving axis:-

$$\text{Error} = (-2000.147\text{mm}) - (-2000.000\text{mm}) = -0.147\text{mm Overtravel.}$$

$$\text{Error} = (-1999.983\text{mm}) - (-2000.000\text{mm}) = +0.017\text{mm Undertravel.}$$

X axis positional results - As Found

Target Position	Error Averages ( $\mu\text{m}$ )		System	$2\sigma$ Std Devn ( $\mu\text{m}$ )		Dead Zone
	Forward	Reverse		Forward	Reverse	
-9.000	0.142	-0.407	-0.132	0.000	0.000	0.549
24.000	1.098	1.024	1.061	0.000	0.000	0.075
57.000	1.845	1.645	1.745	0.000	0.000	0.200
90.000	2.178	2.230	2.204	0.000	0.000	-0.052
123.000	2.663	2.354	2.508	0.000	0.000	0.308
156.000	3.157	2.781	2.969	0.000	0.000	0.376
189.000	4.145	3.993	4.069	0.000	0.000	0.153
222.000	4.975	4.700	4.838	0.000	0.000	0.274
255.000	4.621	4.550	4.586	0.000	0.000	0.071
288.000	5.473	5.438	5.455	0.000	0.000	0.035
321.000	5.979	5.861	5.920	0.000	0.000	0.118
354.000	5.527	5.454	5.491	0.000	0.000	0.073
387.000	6.811	6.905	6.858	0.000	0.000	-0.094
420.000	8.344	8.346	8.345	0.000	0.000	-0.002
453.000	8.226	8.339	8.283	0.000	0.000	-0.113
486.000	8.408	8.549	8.479	0.000	0.000	-0.141

Analysis to ISO 230:Part 2:2006 Linear Positioning







Mean reversal value	= 0.11 $\mu\text{m}$
Mean bidir positional devn	= 8.61 $\mu\text{m}$
Air pressure	= 772.58/772.72 mm Hg
Air humidity	= 50/50 % rel
Air temperature	= 21.799/21.826 $^{\circ}\text{C}$
M/C temperature	= 19.095/19.104 $^{\circ}\text{C}$
Exp coefficient (Scale)	= 8.0 ppm/ $^{\circ}\text{C}$
Air compensation	= 725.87/725.93 ppm
Total compensation	= 733.07/736.46 ppm
Traceability reference	= NPL LL0101/0709

# X AXIS POSITIONAL ERROR (ISO 230)

Machine : DMG DMC50V  
 Serial No : 2880-0338  
 Date : 20 Mar 2009 at 13:00  
 Inspector : A J Gregory  
 Customer : Thomas Keating Ltd

Mean bidir positional devn = 8.61  $\mu\text{m}$   
 Mean Reversal Value = 0.11  $\mu\text{m}$   
 As Found

— Sys Avg — For Avg — Rev Avg



### Test Details

Forward travels : 1  
 Reverse travels : 1  
 Targets : 16  
 Target window : 0.5000 mm  
 Samples : 120  
 Bandwidth : 0.0010 mm  
 Steptype : Linear  
 Pitch : 0.0000 mm  
 Instrument : Agilent 5529 Laser  
 Radius/Dia : Radial  
 Control : Closed loop (CNC)  
 Static/Fly : Static  
 Sample delay : 0.00 seconds



X axis positional results - No Compensation

Target Position	Error Averages ( $\mu\text{m}$ )			System	$2\sigma$ Std Devn ( $\mu\text{m}$ )		Dead Zone
	Forward	Reverse			Forward	Reverse	
-9.000	-0.071	-0.191	-0.131	0.231	0.200	0.120	
24.000	2.859	2.685	2.772	0.518	0.186	0.174	
57.000	4.383	4.173	4.278	0.539	0.364	0.210	
90.000	5.034	4.614	4.824	0.311	0.360	0.420	
123.000	4.775	4.308	4.542	0.448	0.360	0.467	
156.000	4.879	4.448	4.663	0.358	0.255	0.431	
189.000	5.814	5.359	5.587	0.520	0.269	0.455	
222.000	6.737	6.461	6.599	0.775	0.454	0.275	
255.000	7.792	7.438	7.615	0.416	0.478	0.354	
288.000	9.052	8.659	8.855	0.479	0.303	0.393	
321.000	9.852	9.354	9.603	0.516	0.366	0.498	
354.000	8.633	8.177	8.405	0.532	0.217	0.456	
387.000	8.282	7.882	8.082	0.604	0.397	0.400	
420.000	7.820	7.505	7.662	0.695	0.475	0.315	
453.000	6.470	6.415	6.442	0.487	0.377	0.055	
486.000	5.961	5.913	5.937	0.699	0.528	0.048	

Analysis to ISO 230:Part 2:2006 Linear Positioning

Accuracy = 10.76  $\mu\text{m}$   
 Unidirectional repeatability = 1.55  $\mu\text{m}$  at 222.000 mm, forward direction  
 Bidirectional Repeatability = 1.55  $\mu\text{m}$  at 222.000 mm  
 Mean reversal value = 0.32  $\mu\text{m}$   
 Mean bidir positional devn = 9.73  $\mu\text{m}$







Air pressure = 772.54/772.70 mm Hg  
 Air humidity = 50/50 % rel  
 Air temperature = 21.799/21.904  $^{\circ}\text{C}$   
 M/C temperature = 19.124/19.161  $^{\circ}\text{C}$   
 Exp coefficient (Scale) = 8.0 ppm/ $^{\circ}\text{C}$   
 Air compensation = 725.88/726.02 ppm  
 Total compensation = 732.59/736.19 ppm  
 Traceability reference = NPL LL0101/0709

# X AXIS POSITIONAL ERROR (ISO 230)

Machine : DMG DMC50V  
 Serial No : 2880-0338  
 Date : 20 Mar 2009 at 13:32  
 Inspector : A J Gregory  
 Customer : Thomas Keating Ltd

Accuracy = 10.76  $\mu\text{m}$   
 Uni-Direction Repeat = 1.55  $\mu\text{m}$   
 Bi-Direction Repeat = 1.55  $\mu\text{m}$   
 Mean Reversal Value = 0.32  $\mu\text{m}$   
 No Compensation

— Red Avg — Cyan Avg — Blue Avg — +2 Sigma — -2 Sigma



### Test Details

Forward travels : 5  
 Reverse travels : 5  
 Targets : 16  
 Target window : 0.5000 mm  
 Samples : 120  
 Bandwidth : 0.0010 mm  
 Steptype : Linear  
 Pitch : 0.0000 mm  
 Instrument : Agilent 5529 Laser  
 Radius/Dia : Radial  
 Control : Open loop (NC)  
 Static/Fly : Static  
 Sample delay : 0.00 seconds



X axis positional results - With Compensation

Target Position	Error Averages ( $\mu\text{m}$ )		System	$2\sigma$ Std Devn ( $\mu\text{m}$ )		Dead Zone
	Forward	Reverse		Forward	Reverse	
-9.000	0.136	-0.061	0.038	0.276	0.221	0.197
24.000	0.011	-0.255	-0.122	0.122	0.099	0.267
57.000	0.124	-0.274	-0.075	0.148	0.052	0.399
90.000	0.284	-0.227	0.029	0.069	0.125	0.511
123.000	0.157	-0.528	-0.185	0.174	0.185	0.684
156.000	0.189	-0.357	-0.084	0.117	0.144	0.546
189.000	0.060	-0.368	-0.154	0.206	0.325	0.428
222.000	0.186	-0.364	-0.089	0.184	0.298	0.550
255.000	0.116	-0.319	-0.101	0.217	0.123	0.435
288.000	0.110	-0.304	-0.097	0.198	0.301	0.414
321.000	0.178	-0.371	-0.096	0.118	0.155	0.549
354.000	-0.051	-0.565	-0.308	0.135	0.291	0.514
387.000	0.364	0.052	0.208	0.239	0.111	0.313
420.000	0.180	-0.045	0.067	0.158	0.310	0.225
453.000	-0.128	-0.044	-0.086	0.212	0.216	-0.084
486.000	-0.200	-0.235	-0.217	0.183	0.278	0.035

Analysis to ISO 230:Part 2:2006 Linear Positioning

Accuracy = 1.46  $\mu\text{m}$   
 Unidirectional repeatability = 0.65  $\mu\text{m}$  at 189.000 mm, reverse direction  
 Bidirectional Repeatability = 1.04  $\mu\text{m}$  at 123.000 mm  
 Mean reversal value = 0.37  $\mu\text{m}$   
 Mean bidir positional devn = 0.52  $\mu\text{m}$

Air pressure = 772.39/772.62 mm Hg  
 Air humidity = 50/50 % rel  
 Air temperature = 21.753/21.794  $^{\circ}\text{C}$   
 M/C temperature = 19.177/19.221  $^{\circ}\text{C}$   
 Exp coefficient (Scale) = 8.0 ppm/ $^{\circ}\text{C}$   
 Air compensation = 725.86/725.98 ppm  
 Total compensation = 732.17/735.51 ppm  
 Traceability reference = NPL LL0101/0709









# X AXIS POSITIONAL ERROR (ISO 230)

Machine : DMG DMC50V  
 Serial No : 2880-0338  
 Date : 20 Mar 2009 at 13:49  
 Inspector : A J Gregory  
 Customer : Thomas Keating Ltd

Accuracy = 1.46  $\mu$ m  
 Uni-Direction Repeat = 0.65  $\mu$ m  
 Bi-Direction Repeat = 1.04  $\mu$ m  
 Mean Reversal Value = 0.37  $\mu$ m  
 With Compensation

— Sys Avg — For Avg — Rev Avg — +2 Sigma — -2 Sigma



## Test Details

Forward travels : 5  
 Reverse travels : 5  
 Targets : 16  
 Target window : 0.5000 mm  
 Samples : 120  
 Bandwidth : 0.0010 mm  
 Steptype : Linear  
 Pitch : 0.0000 mm  
 Instrument : Agilent 5529 Laser  
 Radius/Dia : Radial  
 Control : Open loop (NC)  
 Static/Fly : Static  
 Sample delay : 0.00 seconds



Y axis positional results - As Found

Target Position	Error Averages (µm)		System	2σ Std Devn (µm)		Dead Zone
	Forward	Reverse		Forward	Reverse	
-12.000	0.138	-0.071	0.033	0.000	0.000	0.209
10.000	0.330	0.247	0.289	0.000	0.000	0.084
32.000	1.007	0.891	0.949	0.000	0.000	0.116
54.000	1.231	1.108	1.170	0.000	0.000	0.123
76.000	1.355	1.301	1.328	0.000	0.000	0.053
98.000	1.702	1.346	1.524	0.000	0.000	0.356
120.000	1.479	1.326	1.403	0.000	0.000	0.153
142.000	1.260	1.069	1.165	0.000	0.000	0.191
164.000	1.007	0.648	0.828	0.000	0.000	0.359
186.000	0.462	0.055	0.258	0.000	0.000	0.407
208.000	0.285	-0.160	0.062	0.000	0.000	0.445
230.000	0.272	-0.179	0.046	0.000	0.000	0.451
252.000	0.465	0.151	0.308	0.000	0.000	0.314
274.000	0.558	0.251	0.405	0.000	0.000	0.307
296.000	0.650	0.398	0.524	0.000	0.000	0.253
318.000	0.730	0.465	0.597	0.000	0.000	0.265
340.000	0.796	0.040	0.418	0.000	0.000	0.757
362.000	0.684	0.343	0.514	0.000	0.000	0.341
384.000	0.880	0.580	0.730	0.000	0.000	0.301
406.000	0.918	0.941	0.929	0.000	0.000	-0.023

Analysis to ISO 230:Part 2:2006 Linear Positioning







Mean reversal value = 0.27 µm  
 Mean bidir positional devn = 1.49 µm  
  
 Air pressure = 772.17/772.35 mm Hg  
 Air humidity = 50/50 % rel  
 Air temperature = 21.858/21.872 °C  
 M/C temperature = 19.346/19.365 °C  
 Exp coefficient (Scale) = 8.0 ppm/°C  
 Air compensation = 726.06/726.12 ppm  
 Total compensation = 731.18/733.73 ppm  
 Traceability reference = NPL LL0101/0709

# Y AXIS POSITIONAL ERROR (ISO 230)

Machine : DMG DMC50V  
 Serial No : 2880-0338  
 Date : 20 Mar 2009 at 14:22  
 Inspector : A J Gregory  
 Customer : Thomas Keating Ltd

Mean bidir positional devn = 1.49  $\mu\text{m}$   
 Mean Reversal Value = 0.27  $\mu\text{m}$   
 As Found

— Sys Avg — For Avg — Rev Avg



## Test Details

Forward travels : 1  
 Reverse travels : 1  
 Targets : 20  
 Target window : 0.5000 mm  
 Samples : 120  
 Bandwidth : 0.0010 mm  
 Steptype : Linear  
 Pitch : 0.0000 mm  
 Instrument : Agilent 5529 Laser  
 Radius/Dia : Radial  
 Control : Closed loop (CNC)  
 Static/Fly : Static  
 Sample delay : 0.00 seconds

**C. D. Measurements Ltd**



Y axis positional results - No Compensation

Target Position	Error Averages ( $\mu\text{m}$ )			2 $\sigma$ Std Devn ( $\mu\text{m}$ )			Dead Zone
	Forward	Reverse	System	Forward	Reverse		
-12.000	0.013	0.131	0.072	0.108	0.105		-0.118
10.000	0.384	0.523	0.453	0.108	0.089		-0.139
32.000	0.629	0.661	0.645	0.203	0.141		-0.032
54.000	0.571	0.537	0.554	0.210	0.103		0.034
76.000	1.114	0.996	1.055	0.100	0.091		0.118
98.000	1.037	0.920	0.979	0.147	0.121		0.117
120.000	0.851	0.728	0.789	0.188	0.284		0.123
142.000	0.811	0.640	0.725	0.191	0.235		0.171
164.000	0.421	0.287	0.354	0.158	0.175		0.134
186.000	-0.231	-0.469	-0.350	0.410	0.375		0.238
208.000	-0.659	-1.042	-0.851	0.248	0.213		0.383
230.000	-0.843	-1.218	-1.030	0.356	0.153		0.375
252.000	-0.634	-0.940	-0.787	0.414	0.130		0.305
274.000	-0.624	-0.989	-0.807	0.271	0.171		0.365
296.000	-0.754	-1.040	-0.897	0.216	0.165		0.286
318.000	-0.581	-1.042	-0.811	0.043	0.304		0.461
340.000	-0.956	-1.413	-1.184	0.166	0.142		0.457
362.000	-0.927	-1.328	-1.127	0.228	0.180		0.400
384.000	-1.005	-1.228	-1.116	0.196	0.321		0.223
406.000	-1.329	-1.314	-1.321	0.212	0.152		-0.015

Analysis to ISO 230:Part 2:2006 Linear Positioning







Accuracy	= 2.77 $\mu\text{m}$
Unidirectional repeatability	= 0.83 $\mu\text{m}$ at 252.000 mm, forward direction
Bidirectional Repeatability	= 1.02 $\mu\text{m}$ at 186.000 mm
Mean reversal value	= 0.19 $\mu\text{m}$
Mean bidir positional devn	= 2.38 $\mu\text{m}$
Air pressure	= 772.17/772.31 mm Hg
Air humidity	= 50/50 % rel
Air temperature	= 21.890/21.988 $^{\circ}\text{C}$
M/C temperature	= 19.384/19.451 $^{\circ}\text{C}$
Exp coefficient (Scale)	= 8.0 ppm/ $^{\circ}\text{C}$
Air compensation	= 726.10/726.23 ppm
Total compensation	= 730.60/733.31 ppm
Traceability reference	= NPL LL0101/0709

# Y AXIS POSITIONAL ERROR (ISO 230)

Machine : DMG DMC50V  
 Serial No : 2880-0338  
 Date : 20 Mar 2009 at 14:30  
 Inspector : A J Gregory  
 Customer : Thomas Keating Ltd

Accuracy = 2.77  $\mu\text{m}$   
 Uni-Direction Repeat = 0.83  $\mu\text{m}$   
 Bi-Direction Repeat = 1.02  $\mu\text{m}$   
 Mean Reversal Value = 0.19  $\mu\text{m}$   
 No Compensation

— Sys Avg — For Avg — Rev Avg — +2 Sigma — -2 Sigma



## Test Details

Forward travels : 5  
 Reverse travels : 5  
 Targets : 20  
 Target window : 0.5000 mm  
 Samples : 120  
 Bandwidth : 0.0010 mm  
 Steptype : Linear  
 Pitch : 0.0000 mm  
 Instrument : Agilent 5529 Laser  
 Radius/Dia : Radial  
 Control : Open loop (NC)  
 Static/Fly : Static  
 Sample delay : 0.00 seconds



Y axis positional results - With Compensation

Target Position	Error Averages ( $\mu\text{m}$ )		System	2 $\sigma$ Std Devn ( $\mu\text{m}$ )		Dead Zone
	Forward	Reverse		Forward	Reverse	
-12.000	-0.023	0.028	0.003	0.105	0.081	-0.052
10.000	-0.101	-0.063	-0.082	0.156	0.276	-0.038
32.000	-0.032	-0.091	-0.061	0.086	0.140	0.059
54.000	-0.198	-0.229	-0.214	0.081	0.139	0.031
76.000	-0.116	-0.171	-0.144	0.163	0.180	0.054
98.000	-0.194	-0.179	-0.186	0.121	0.042	-0.015
120.000	-0.137	-0.246	-0.191	0.191	0.181	0.108
142.000	-0.166	-0.280	-0.223	0.190	0.175	0.114
164.000	0.148	-0.143	0.002	0.251	0.337	0.291
186.000	0.322	0.023	0.173	0.259	0.234	0.299
208.000	0.415	-0.030	0.193	0.190	0.164	0.445
230.000	0.270	-0.086	0.092	0.277	0.232	0.356
252.000	0.311	-0.087	0.112	0.272	0.229	0.398
274.000	0.273	0.010	0.142	0.119	0.237	0.262
296.000	0.227	-0.073	0.077	0.100	0.180	0.300
318.000	0.235	-0.036	0.099	0.243	0.170	0.271
340.000	0.370	0.007	0.189	0.408	0.289	0.363
362.000	0.301	-0.188	0.057	0.154	0.149	0.489
384.000	0.464	0.130	0.297	0.428	0.154	0.334
406.000	0.177	0.147	0.162	0.526	0.364	0.030

Analysis to ISO 230:Part 2:2006 Linear Positioning







Accuracy	= 1.37 $\mu\text{m}$
Unidirectional repeatability	= 1.05 $\mu\text{m}$ at 406.000 mm, forward direction
Bidirectional Repeatability	= 1.06 $\mu\text{m}$ at 340.000 mm
Mean reversal value	= 0.21 $\mu\text{m}$
Mean bidir positional devn	= 0.52 $\mu\text{m}$
Air pressure	= 772.09/772.29 mm Hg
Air humidity	= 50/50 % rel
Air temperature	= 21.854/21.988 $^{\circ}\text{C}$
M/C temperature	= 19.459/19.509 $^{\circ}\text{C}$
Exp coefficient (Scale)	= 8.0 ppm/ $^{\circ}\text{C}$
Air compensation	= 726.10/726.25 ppm
Total compensation	= 730.03/732.53 ppm
Traceability reference	= NPL LL0101/0709

# Y AXIS POSITIONAL ERROR (ISO 230)

Machine : DMG DMC50V  
 Serial No : 2880-0338  
 Date : 20 Mar 2009 at 14:49  
 Inspector : A J Gregory  
 Customer : Thomas Keating Ltd

Accuracy = 1.37  $\mu\text{m}$   
 Uni-Direction Repeat = 1.05  $\mu\text{m}$   
 Bi-Direction Repeat = 1.06  $\mu\text{m}$   
 Mean Reversal Value = 0.21  $\mu\text{m}$   
 With Compensation

— Red Avg — Cyan Avg — Blue Avg — Green +2 Sigma — Green -2 Sigma



## Test Details

Forward travels : 5  
 Reverse travels : 5  
 Targets : 20  
 Target window : 0.5000 mm  
 Samples : 120  
 Bandwidth : 0.0010 mm  
 Steptype : Linear  
 Pitch : 0.0000 mm  
 Instrument : Agilent 5529 Laser  
 Radius/Dia : Radial  
 Control : Open loop (NC)  
 Static/Fly : Static  
 Sample delay : 0.00 seconds

**C. D. Measurements Ltd**



Z axis positional results - As Found

Target Position	Error Averages ( $\mu\text{m}$ )		System	$2\sigma$ Std Devn ( $\mu\text{m}$ )		Dead Zone
	Forward	Reverse		Forward	Reverse	
-486.000	0.096	0.028	0.062	0.000	0.000	0.067
-453.000	0.813	0.658	0.735	0.000	0.000	0.155
-420.000	1.228	0.948	1.088	0.000	0.000	0.280
-387.000	1.536	1.221	1.378	0.000	0.000	0.315
-354.000	1.825	1.508	1.666	0.000	0.000	0.317
-321.000	2.556	2.202	2.379	0.000	0.000	0.354
-288.000	3.170	2.827	2.999	0.000	0.000	0.343
-255.000	4.048	3.588	3.818	0.000	0.000	0.459
-222.000	4.687	4.166	4.427	0.000	0.000	0.521
-189.000	5.324	4.980	5.152	0.000	0.000	0.344
-156.000	5.869	5.454	5.662	0.000	0.000	0.415
-123.000	6.704	6.303	6.503	0.000	0.000	0.401
-90.000	7.346	6.859	7.102	0.000	0.000	0.486
-57.000	7.846	7.395	7.621	0.000	0.000	0.451
-24.000	8.213	7.934	8.074	0.000	0.000	0.279
9.000	8.468	8.371	8.420	0.000	0.000	0.097

Analysis to ISO 230:Part 2:2006 Linear Positioning

Mean reversal value	= 0.33 $\mu\text{m}$
Mean bidir positional devn	= 8.36 $\mu\text{m}$
Air pressure	= 772.02/772.15 mm Hg
Air humidity	= 50/50 % rel
Air temperature	= 21.737/21.749 $^{\circ}\text{C}$
M/C temperature	= 19.572/19.578 $^{\circ}\text{C}$
Exp coefficient (Scale)	= 8.0 ppm/ $^{\circ}\text{C}$
Air compensation	= 726.01/726.06 ppm
Total compensation	= 729.38/731.02 ppm
Traceability reference	= NPL LL0101/0709









# Z AXIS POSITIONAL ERROR (ISO 230)

Machine : DMG DMC50V  
 Serial No : 2880-0338  
 Date : 20 Mar 2009 at 15:15  
 Inspector : A J Gregory  
 Customer : Thomas Keating Ltd

Mean bidir positional devn = 8.36  $\mu$ m  
 Mean Reversal Value = 0.33  $\mu$ m  
 As Found

— Sys Avg — For Avg — Rev Avg



## Test Details

Forward travels : 1  
 Reverse travels : 1  
 Targets : 16  
 Target window : 0.5000 mm  
 Samples : 120  
 Bandwidth : 0.0010 mm  
 Steptype : Linear  
 Pitch : 0.0000 mm  
 Instrument : Agilent 5529 Laser  
 Radius/Dia : Radial  
 Control : Closed loop (CNC)  
 Static/Fly : Static  
 Sample delay : 0.00 seconds

**C. D. Measurements Ltd**



Z axis positional results - No Compensation

Target Position	Error Averages ( $\mu\text{m}$ )			System	2 $\sigma$ Std Devn ( $\mu\text{m}$ )		Dead Zone
	Forward	Reverse			Forward	Reverse	
-486.000	-0.057	-0.039	-0.048	0.244	0.159	-0.018	
-453.000	2.113	2.061	2.087	0.277	0.152	0.052	
-420.000	3.864	3.733	3.798	0.208	0.110	0.131	
-387.000	5.292	5.056	5.174	0.315	0.186	0.236	
-354.000	6.779	6.454	6.616	0.336	0.183	0.325	
-321.000	8.520	8.144	8.332	0.399	0.171	0.376	
-288.000	10.026	9.715	9.870	0.318	0.186	0.311	
-255.000	11.818	11.413	11.616	0.388	0.219	0.406	
-222.000	13.427	13.001	13.214	0.338	0.325	0.426	
-189.000	14.947	14.548	14.748	0.271	0.339	0.400	
-156.000	16.338	15.967	16.152	0.451	0.394	0.372	
-123.000	17.891	17.579	17.735	0.474	0.342	0.312	
-90.000	19.750	19.482	19.616	0.334	0.316	0.268	
-57.000	21.764	21.497	21.631	0.250	0.376	0.267	
-24.000	24.066	23.783	23.924	0.517	0.468	0.283	
9.000	25.344	25.250	25.297	0.738	0.658	0.094	

Analysis to ISO 230:Part 2:2006 Linear Positioning

Accuracy = 26.38  $\mu\text{m}$   
 Unidirectional repeatability = 1.48  $\mu\text{m}$  at 9.000 mm, forward direction  
 Bidirectional Repeatability = 1.49  $\mu\text{m}$  at 9.000 mm  
 Mean reversal value = 0.27  $\mu\text{m}$   
 Mean bidir positional devn = 25.35  $\mu\text{m}$







Air pressure = 771.96/772.17 mm Hg  
 Air humidity = 50/50 % rel  
 Air temperature = 21.532/21.685  $^{\circ}\text{C}$   
 M/C temperature = 19.581/19.602  $^{\circ}\text{C}$   
 Exp coefficient (Scale) = 8.0 ppm/ $^{\circ}\text{C}$   
 Air compensation = 725.84/726.00 ppm  
 Total compensation = 729.03/730.86 ppm  
 Traceability reference = NPL LL0101/0709

# Z AXIS POSITIONAL ERROR (ISO 230)

Machine : DMG DMC50V  
 Serial No : 2880-0338  
 Date : 20 Mar 2009 at 15:27  
 Inspector : A J Gregory  
 Customer : Thomas Keating Ltd

Accuracy = 26.38  $\mu\text{m}$   
 Uni-Direction Repeat = 1.48  $\mu\text{m}$   
 Bi-Direction Repeat = 1.49  $\mu\text{m}$   
 Mean Reversal Value = 0.27  $\mu\text{m}$   
 No Compensation

— Sys Avg — For Avg — Rev Avg — +2 Sigma — -2 Sigma



## Test Details

Forward travels : 5  
 Reverse travels : 5  
 Targets : 16  
 Target window : 0.5000 mm  
 Samples : 120  
 Bandwidth : 0.0010 mm  
 Steptype : Linear  
 Pitch : 0.0000 mm  
 Instrument : Agilent 5529 Laser  
 Radius/Dia : Radial  
 Control : Open loop (NC)  
 Static/Fly : Static  
 Sample delay : 0.00 seconds

**C. D. Measurements Ltd**



Z axis positional results - With Compensation

Target Position	Error Averages ( $\mu\text{m}$ )		System	$2\sigma$ Std Devn ( $\mu\text{m}$ )		Dead Zone
	Forward	Reverse		Forward	Reverse	
-486.000	-0.274	-0.301	-0.287	0.348	0.157	0.027
-453.000	-0.253	-0.365	-0.309	0.349	0.163	0.112
-420.000	-0.325	-0.549	-0.437	0.317	0.157	0.223
-387.000	-0.264	-0.560	-0.412	0.270	0.241	0.296
-354.000	-0.316	-0.651	-0.483	0.379	0.324	0.335
-321.000	-0.018	-0.403	-0.210	0.337	0.379	0.385
-288.000	-0.045	-0.444	-0.245	0.382	0.319	0.399
-255.000	-0.124	-0.525	-0.324	0.419	0.357	0.401
-222.000	-0.258	-0.647	-0.453	0.283	0.275	0.389
-189.000	-0.188	-0.642	-0.415	0.260	0.274	0.453
-156.000	-0.234	-0.836	-0.535	0.526	0.433	0.603
-123.000	-0.179	-0.767	-0.473	0.558	0.407	0.588
-90.000	-0.277	-0.737	-0.507	0.566	0.401	0.460
-57.000	-0.329	-0.645	-0.487	0.460	0.366	0.315
-24.000	-0.320	-0.587	-0.454	0.589	0.275	0.267
9.000	-0.549	-0.665	-0.607	0.522	0.453	0.116

Analysis to ISO 230:Part 2:2006 Linear Positioning







Accuracy	= 1.65 $\mu\text{m}$
Unidirectional repeatability	= 1.18 $\mu\text{m}$ at -24.000 mm, forward direction
Bidirectional Repeatability	= 1.56 $\mu\text{m}$ at -156.000 mm
Mean reversal value	= 0.34 $\mu\text{m}$
Mean bidir positional devn	= 0.40 $\mu\text{m}$
Air pressure	= 771.94/772.15 mm Hg
Air humidity	= 50/50 % rel
Air temperature	= 21.487/21.535 $^{\circ}\text{C}$
M/C temperature	= 19.610/19.637 $^{\circ}\text{C}$
Exp coefficient (Scale)	= 8.0 ppm/ $^{\circ}\text{C}$
Air compensation	= 725.79/725.88 ppm
Total compensation	= 728.74/730.38 ppm
Traceability reference	= NPL LL0101/0709

# Z AXIS POSITIONAL ERROR (ISO 230)

Machine : DMG DMC50V  
 Serial No : 2880-0338  
 Date : 20 Mar 2009 at 15:43  
 Inspector : A J Gregory  
 Customer : Thomas Keating Ltd

Accuracy = 1.65  $\mu$ m  
 Uni-Direction Repeat = 1.18  $\mu$ m  
 Bi-Direction Repeat = 1.56  $\mu$ m  
 Mean Reversal Value = 0.34  $\mu$ m  
 With Compensation

— Sys Avg — For Avg — Rev Avg — +2 Sigma — -2 Sigma



## Test Details

Forward travels : 5  
 Reverse travels : 5  
 Targets : 16  
 Target window : 0.5000 mm  
 Samples : 120  
 Bandwidth : 0.0010 mm  
 Steptype : Linear  
 Pitch : 0.0000 mm  
 Instrument : Agilent 5529 Laser  
 Radius/Dia : Radial  
 Control : Open loop (NC)  
 Static/Fly : Static  
 Sample delay : 0.00 seconds



# CERTIFICATE OF CALIBRATION

Issued by CD Measurements Ltd. UKAS Laboratory No 0334

---

This laboratory is accredited in accordance with the recognised International Standard ISO/IEC 17025:2005. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system.

The joint ISO-ILAC-IAF communiqué can be found at [www.cdmeasurements.com/downloads.htm](http://www.cdmeasurements.com/downloads.htm) which clarifies the relationship between ISO9001:2000 and ISO17025:2005.

---

# CERTIFICATE OF CALIBRATION

Issued by : **CD MEASUREMENTS LIMITED**  
Chomlea House, Hadfield Road, Hadfield, Glossop, Derbyshire, SK13 2ER.  
Telephone : 01457 852929 Facsimile : 01457 860619  
Email : calibration@cdmeasurements.com



0334

Certificate Number : 02667  
Date of Issue : 27 Mar 2009  
Basis of Test : ISO 230:Part 2:2006 Linear Positioning

Page 1 of 2 Pages

Approved Signatory

A. Butterworth

Customer & Site location : Thomas Keating Ltd  
Station Mills  
Billingshurst  
West Sussex  
RH14 9SH

Machine : DMG DMC50V

Serial No : 2880-0338

Method : This machine was calibrated on 20 Mar 2009 at the above site location as follows:-  
Agilent 5529 laser interferometer and the above specification.  
The results corrected to 20 °C are shown on the following sheet.

Uncertainty :  $\pm (0.15 \mu\text{m} + 0.93 \mu\text{m}/\text{metre})$

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor  $k=2$ , providing a level of confidence of approximately 95%. The uncertainty evaluation has been carried out in accordance with UKAS requirements.

This certificate is issued in accordance with the laboratory accreditation requirements of the United Kingdom Accreditation Service. It provides traceability of measurement to recognised national standards, and to units of measurement realised at the National Physical Laboratory or other recognised national standards laboratories. This certificate may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.

# CERTIFICATE OF CALIBRATION

UKAS ACCREDITED CALIBRATION LABORATORY No. 0334

Date of Issue  
27 Mar 2009

Certificate Number  
02667

Page 2 of 2 Pages

X axis positional results : Tested from -9.0mm to 486.0mm @ Y182.0 Z-447.0  
: With Compensation

Accuracy	= 1.46 $\mu\text{m}$
Unidirectional repeatability	= 0.65 $\mu\text{m}$ at 189.000 mm, reverse direction
Bidirectional Repeatability	= 1.04 $\mu\text{m}$ at 123.000 mm
Mean reversal value	= 0.37 $\mu\text{m}$
Mean bidir positional devn	= 0.52 $\mu\text{m}$
Air pressure	= 772.39/772.62 mm Hg
Air humidity	= 50/50 % rel
Air temperature	= 21.753/21.794 $^{\circ}\text{C}$
M/C temperature	= 19.177/19.221 $^{\circ}\text{C}$
Exp coefficient (Scale)	= 8.0 ppm/ $^{\circ}\text{C}$
Air compensation	= 725.86/725.98 ppm
Total compensation	= 732.17/735.51 ppm

Y axis positional results : Tested from -12.0mm to 406.0mm @ X216.3 Z-428.7  
: With Compensation

Accuracy	= 1.37 $\mu\text{m}$
Unidirectional repeatability	= 1.05 $\mu\text{m}$ at 406.000 mm, forward direction
Bidirectional Repeatability	= 1.06 $\mu\text{m}$ at 340.000 mm
Mean reversal value	= 0.21 $\mu\text{m}$
Mean bidir positional devn	= 0.52 $\mu\text{m}$
Air pressure	= 772.09/772.29 mm Hg
Air humidity	= 50/50 % rel
Air temperature	= 21.854/21.988 $^{\circ}\text{C}$
M/C temperature	= 19.459/19.509 $^{\circ}\text{C}$
Exp coefficient (Scale)	= 8.0 ppm/ $^{\circ}\text{C}$
Air compensation	= 726.10/726.25 ppm
Total compensation	= 730.03/732.53 ppm

Z axis positional results : Tested from -486.0mm to 9.0mm @ X247.2 Y161.7  
: With Compensation

Accuracy	= 1.65 $\mu\text{m}$
Unidirectional repeatability	= 1.18 $\mu\text{m}$ at -24.000 mm, forward direction
Bidirectional Repeatability	= 1.56 $\mu\text{m}$ at -156.000 mm
Mean reversal value	= 0.34 $\mu\text{m}$
Mean bidir positional devn	= 0.40 $\mu\text{m}$
Air pressure	= 771.94/772.15 mm Hg
Air humidity	= 50/50 % rel
Air temperature	= 21.487/21.535 $^{\circ}\text{C}$
M/C temperature	= 19.610/19.637 $^{\circ}\text{C}$
Exp coefficient (Scale)	= 8.0 ppm/ $^{\circ}\text{C}$
Air compensation	= 725.79/725.88 ppm
Total compensation	= 728.74/730.38 ppm